



## This Issue

The Benefits of Torus **P.1**

## The Benefits of Torus

As a follow up to last month's letter on the advantages of Series Mode Surge Suppression as used in the new TORUS power-line conditioners, please see below an excellent article by Neil Muncy.

There are fundamental differences between 'Shunt Mode' and 'Series Mode' surge suppressors. It can be shown that the indiscriminate use of Shunt Mode surge suppressors in applications such as sound systems, delicate digital systems and computer networks can cause more problems than are supposedly eliminated by the use of such devices.

Multiple sources of transient electrical noise (surges) including motors, HVAC equipment, photocopiers, power tools, etc. are present in all modern buildings. Surge energy conveyed by building power systems may also result from external sources such as nearby lightning strikes.

To minimize the likelihood of injuries to personnel and damage to equipment due to electrical surges and accidental fault conditions, in North America the National Electrical Code (NEC) specifies that all exposed electrical equipment in building electrical systems is to be connected ("bonded") together and ultimately bonded ("grounded") to an earth "Building Ground" connection at the electrical Service Entrance. This requirement is addressed by the building Equipment Grounding system. Equipment Grounding (EG) systems incorporates combinations of conduits, raceways, and dedicated Equipment Ground conductors associated with the Hot and Neutral conductors of branch circuits.

Connections to EG systems are made via the "U-Ground" contacts (often referred to as the "Green Wire") in electrical outlets. By merely being "plugged-in", installations of electronic equipment (computers, sound systems, etc.) are automatically "grounded" and thus made as safe as possible for operation by non-technical personnel.


### NORMAL EQUIPMENT INTERCONNECTIONS CREATE "GROUND LOOPS"

Interconnections between groups of grounded electronic equipment via "network" cables (which incorporate dedicated signal and shield "ground" conductors) are commonplace. Inductive coupling of power line surge energy into the "Ground Loops" formed by these multiple "ground" connections is inevitable, as current will flow in any conductive path (loop) exposed to the magnetic fields associated with nearby power conductors and electrical equipment. The consequences often appear as noise in sound systems, and mysterious computer network problems rang-

ing from data corruption all the way to catastrophic failure of interface devices, and will be especially evident in installations involving equipment with Pin-1 Problems [1].

It is often suggested that "surge suppressors" (devices which limit the magnitude of surge energy) might address these problems. Power "Outlet Bars" with internal "Shunt Mode" circuitry are obtained and installed in various equipment locations throughout the building. While perhaps surprising, it is not unusual to find that the net results from these efforts often range from no





difference at all through vague “improvements” to outright worsening of the original problem(s).

In some cases the “improvements” first realized will unpredictably disappear after some time for no apparent reason.

#### SHUNT MODE SURGE SUPPRESSORS

Shunt Mode surge suppressors operate by redirecting (shunting) incoming surge energy onto their associated EG conductors, with the result that the local ground reference potential rises due to the current flow through the impedance of the circuit path back to Building Ground. For a ground path length of more than a few feet, this impedance can be substantial, resulting in significant voltages with respect to other “grounded” areas in the building.

Any and all equipment connected to a Shunt Mode surge protection device will thus experience an abrupt elevation of its local EG reference potential during surge events.

For non-networked stand-alone applications this may be an academic issue. The additional drawbacks described below are considerably more serious, however.

Metal Oxide Varistors (MOV’s), the principal component(s) which divert incoming surge energy into EG conductors in virtually all Shunt Mode surge suppressors, exhibit a “fixed clamping voltage” characteristic, above which they rapidly change from virtual open circuits into low resistance conductors. For transient surge duration of not more than a few milliseconds, the resulting power dissipation in MOV’s can be tolerated. In the event of a continuous over-voltage condition of any significant duration however, MOV’s rapidly heat up and then either permanently revert to their non-conductive state, or fail catastrophically with the attendant possibility of fire.

Irrespective of cost or manufacturer, the cumulative

(sacrificial) effect of repeated surges over time will ultimately cause MOV’s to fail one way or the other. Recent MOV based surge suppressor devices made to Underwriters Laboratories (UL) 1449-2 (2nd ed.) specifications incorporate a fuse element which disconnects the power in the event of catastrophic MOV failure. Older MOV-based devices do not have this feature, however, and non-catastrophic MOV failure leaves

#### SHUNT MODE SURGE SUPPRESSORS IN EQUIPMENT NETWORKS

It is not uncommon to encounter “Shunt Mode surge protected” equipment interconnected by network cables to other equipment elsewhere in a building which, for whatever reason are NOT connected to Shunt Mode surge suppressors. During a surge event, “unprotected” equipment will experience little if any elevation of its ground reference potential, whilst “protected” equipment will experience an abrupt and often substantial rise in its ground reference potential. The resulting surge currents flowing in network cable ground loops are thus considerably increased by the use of Shunt Mode surge suppressors at only one or some equipment locations rather than ALL locations involved in the network.

Installing identical Shunt Mode suppressors at all

equipment locations may in fact reduce

the magnitude of this problem, but only to the extent that the impedances of each ground path into which noise energy is shunted are the same, a condition which is not likely to exist in all but the smallest of systems.

#### THE SERIES MODE ALTERNATIVE

Series Mode surge suppressors act first as low pass filters which simply block the high frequency (HF) components of power-line surges. The remaining low-frequency (LF) surge energy is diverted into a bank of





capacitors where it is stored for the duration of the event and then slowly discharged back across the incoming hot and neutral conductors without involving any connection to Equipment Ground.

Series Mode surge suppressors can thus be placed anywhere along a power circuit without the ground reference elevation disadvantage of Shunt Mode surge protection devices. Series Mode surge suppressors incorporate "floating clamping voltage" circuitry which will withstand considerable over-voltage conditions of indefinite duration without damage or degradation of performance, and are UL certified to a Surge Endurance specification of A-1-1, the highest possible rating available [2]. Most importantly, SurgeX Series Mode surge suppressors do not incorporate sacrificial components of any kind, effectively guaranteeing an unlimited service life without the requirement for testing and/or periodic maintenance.

#### THE BOTTOM LINE

During a surge event, Shunt Mode surge suppressors located at the equipment load end of a branch circuit will cause an increase of local ground reference potential regardless of manufacturer and/or price. Without periodic testing there is no guarantee of long-term protection due to the sacrificial nature of key components used in these devices.

Series Mode surge suppressors do not require periodic maintenance or testing, and do not cause an elevation of the local Equipment Ground reference potential during surge events regardless of where they are installed in an electrical power system. This is truly a quantum leap in real power-line SURGE PROTEC-

TION!

Neil A. Muncy

Neil Muncy Associates

Toronto, Canada

References:

[1] N. A. Muncy, Noise Susceptibility in Analog and Digital Signal Processing Systems, J. Audio Eng. Soc., Vol.

43, No. 6, 1995 June

[2] The UL A-1-1 Surge Endurance testing procedure involves the application of a minimum of 1000 surges of 6,000 Volts at 3,000 Amperes (the highest surge voltages and currents likely to be encountered in a typical

building), as specified in IEEE/ANSI C62.41- 1991.

# BRYSTON

A Lifetime of Music

Bryston Ltd.  
677 Neal Drive  
Peterborough, Ontario  
CANADA  
K9J 6X7  
Phone: 705-742-5325 or 1-800-632-8217  
Fax: 705-742-0882  
Email: [contact@bryston.com](mailto:contact@bryston.com)  
Web: <http://www.bryston.com>

Editor: James Tanner, Vice President of Sales and Marketing  
Email: [jamestanner@bryston.com](mailto:jamestanner@bryston.com)